

## **DIVISION 33 - UTILITIES**

### **33 00 00 UTILITIES**

#### **33 10 00 WATER UTILITIES**

1. Fire hydrants: Local fire service provider is to be consulted on fire protection services and should be consulted for locations and type of fire hydrants, and access to building for fire fighting apparatus. Review with GVSU. The hydrant operating nut and nozzle caps shall have a 1-3/4 inch square portion one-inch high. Hydrants to be painted with XO Rust "Gloss Bright Red". By TruValue Manufacturing Company and available at TruValue hardware stores.
2. Provide concrete maintenance pad around covers for shut-off valves to water located on the exterior of buildings. Refer to Standard Detail 22.001 in Appendix C of this manual.
3. University personnel shall be contacted to inspect open trench work prior to backfilling.

END OF SECTION